



## SHARED PURCHASING SERVICE CONSORTIUM OF GREY-BRUCE

Bluewater District School Board  
Bruce-Grey Catholic District School Board  
799 - 16<sup>th</sup> Avenue, Hanover, Ontario N4N 3A1 Telephone (519) 364-0614 Fax (519) 364-5828



---

# Addendum No. 1

## RFQ 24-00022 Request for Quotation

### Playground Equipment for Huron Heights Public School

**Dated: January 29, 2024**

This Addendum shall form an integral part of the Request for Information documents for the above noted RFQ and shall be read in conjunction therewith.



## SHARED PURCHASING SERVICE CONSORTIUM OF GREY-BRUCE

Bluewater District School Board  
Bruce-Grey Catholic District School Board  
799 - 16<sup>th</sup> Avenue, Hanover, Ontario N4N 3A1 Telephone (519) 364-0614 Fax (519) 364-5828



---

This Addendum must be signed by the Proponent in the appropriate space and shall be submitted with the Response documents at the time of closing.

RFQ 24-00022 is modified as set forth in this addendum. The original RFQ document and any previously issued addenda remain in full force and effect, except as modified by this addendum, which is hereby made part of RFQ 24-00022 Playground Equipment for Huron Heights Public School. This addendum shall be taken into consideration by the respondent for the preparation and submission of responses.

Orange colour text is language that has been added to the RFQ. Strike-through text is language being taken out of the RFQ and is no longer being used.

### Question 1:

The Play structure requirements on page 12 of the RFQ documents asks for a side by side slide that is accessible by ramp (not stairs)  
Ramps require a ratio of 1:12. Meaning you need a 12ft ramp to gain 1ft (12inches of height) In order to provide a slide that is accessible by ramp, we would require at least 3 ramps to get to a 3ft height off the ground. The site dimensions and budget do not permit this size of structure. It also states no small slides – so although we could do a 3ft slide, it would be considered a small slide.

Is it possible to exclude the requirement of a ramped structure. We can provide a structure with a transfer station with accessible stairs and include accessible ground level play.

### Answer 1:

Article 2.4 section c states that “the primary play structure should include the following features or features similar to those described below:”. As per the definition included on page 10, should “means recommended/suggested/preferred but not mandatory.” The submission presented to the Board should be completed based on the best design aligning with the budget and timelines listed while including some or all of the requested features as feasible.

I, \_\_\_\_\_, confirm that I/we have received this Addendum No. 1 to RFQ 24-00022 Playground Equipment for Huron Heights Public School. I/We acknowledge that this



**SHARED PURCHASING SERVICE CONSORTIUM OF GREY-BRUCE**

Bluewater District School Board  
Bruce-Grey Catholic District School Board  
799 - 16<sup>th</sup> Avenue, Hanover, Ontario N4N 3A1 Telephone (519) 364-0614 Fax (519) 364-5828



---

Addendum No. 1 RFQ 24-00022 Playground Equipment for Huron Heights Public School creates an integral part of the RFQ documents.

Company Name: \_\_\_\_\_  
(Please Print Clearly)

Name: \_\_\_\_\_  
(Please Print Clearly)

Title: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_